

Input

Area

USA - Boston, Massachusetts Choose location

Heat load [kW]

5 Insert heat generated by equipment.

Set point [°C]

25 Insert temperature set point in shelter.

COP

3 Insert energy-efficiency ratio/coefficient of comparative air conditioner.

Calculated Annual Energy Savings

Air Conditioner only

Annual power consumption 9303 kWh

Air Conditioner + Flexibox 450, 48 V DC

Annual power consumption 2745 kWh
Energy savings 9303 - 2744 kWh 6558 kWh

70%

Above information and subsequent cost saving calculation are estimates only. Each application is different and actual results will vary. All testing and verification of actual performance and cost savings are the responsibility of the customer.

