

### Input

**Area**

Japan - Tokyo Choose location

**Heat load [kW]**

5 Insert heat generated by equipment.

**Set point [°C]**

30 Insert temperature set point in shelter.

**COP**

3 Insert energy-efficiency ratio/coefficient of comparative air conditioner.

### Calculated Annual Energy Savings

**Air Conditioner only**

Annual power consumption 11099 kWh

**Air Conditioner + Flexibox 450, 48 V DC**

Annual power consumption 1799 kWh  
Energy savings 11099 - 1798 kWh 9300 kWh

**84%**

Above information and subsequent cost saving calculation are estimates only. Each application is different and actual results will vary. All testing and verification of actual performance and cost savings are the responsibility of the customer.

